

## Robins, Joel

---

**From:** Planning Department  
**Subject:** FW: OUT/2019/0022 Land at Fivefield Road and Tamworth Road

---

**From:** Taylor, Frances  
**Sent:** 14 May 2019 09:54  
**To:** Smith, Nigel <[Nigel.Smith@coventry.gov.uk](mailto:Nigel.Smith@coventry.gov.uk)>  
**Subject:** RE: OUT/2019/0022 Land at Fivefield Road and Tamworth Road

Hi Nigel,

Thanks for this.

The updated air quality assessment is acceptable and I have the following comments with reference to the updated Environmental Statement relating to air quality:

- Electric vehicle recharging should be provided at the following rate:
  - minimum of 1 per 10 unallocated spaces
  - 1 per property for allocated spaces

Also to be included are the installation of low NOx boilers in all properties.

Regards,

Frances